



Symbol	Qty	Label	LLF	Description	Lum. Watts	Lum. Lumens	(MANUFAC)
[Symbol]	7	P1	0.90	P26-80L-900-CW-G2-BLC	219.4286	20051	Gardco by Signify
[Symbol]	2	P2	0.90	P26-80L-900-CW-G2-SW	219.4286	28991	Gardco by Signify
[Symbol]	3	P3	0.90	P26-80L-700-CW-G2-LCR	167.7	5886	Gardco by Signify
[Symbol]	4	P4	0.90	P34-128L-1050-CW-G2-4-HIS	414.3833	39019	Gardco by Signify
[Symbol]	1	P4	0.90	P26-80L-900-CW-G2-3	219.4286	27064	Gardco by Signify
[Symbol]	1	P5	0.90	P26-80L-900-CW-G2-SW	219.4286	28991	Gardco by Signify

Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
LIGHTSPILL	Illuminance	Fc	0.00	0.2	0.0	N.A.	N.A.
SITE	Illuminance	Fc	2.03	7.1	0.5	4.06	14.20

- ### ELECTRICAL SPECIFICATIONS
- OBTAIN ALL APPROVALS FROM PUBLIC AUTHORITIES WITHIN JURISDICTION, BEFORE COMMENCING WORK AND PAY ALL INSPECTION FEES.
 - PROVIDE PROOF OF PUBLIC LIABILITY AND PROPERTY DAMAGE INSURANCE COVERAGE AND AGENCY, SUBJECT WITH TESTER.
 - EXAMINE SITE AND EXISTING AVAILABLE BUILDING DRAWINGS BEFORE PROCEEDING WITH THE WORK. ANY DISCREPANCIES BETWEEN DRAWINGS AND/OR SPECIFICATIONS MUST BE REFERRED TO THE ARCHITECT BEFORE ANY AFFECTED WORK IS COMMENCED.
 - ALL CUTTING AND PATCHING REQUIRED FOR THE WORK OF THIS DIVISION SHALL BE CARRIED OUT BY THIS DIVISION. NO CHASING, BLOWING OR MILLING SHALL BE ALLOWED. BE RESPONSIBLE AND PAY FOR ANY DAMAGE TO THE BUILDING INCURRED BY WORK OF THIS DIVISION. PROVIDE THE STOPPING TO SUIT FITTING OF THE FLOOR OR WALL PENETRATION TO SUIT.
 - SUBMIT 4 COPIES OF SHOP DRAWINGS FOR REVIEW AND RECORDS.
 - ALL MATERIALS USED THROUGHOUT SHALL BE NEW, OF BEST QUALITY. C.S.A. APPROVED AND OF ONE MANUFACTURE. WHEREVER TRADE NAMES ARE NOT USED TO DESCRIBE MATERIALS, THESE MATERIALS SHALL BE OF BEST AVAILABLE QUALITY AND MANUFACTURE. OBTAIN AND PAY FOR SPECIAL INSPECTION OF SPECIFIED NON-C.S.A. ELECTRICAL EQUIPMENT.
 - PROVIDE ALL CONDUIT, WIRING, BOXES, DEVICES, ETC., AS REQUIRED. UNDERGROUND CONDUIT MINIMUM 600MM (24") BELOW GRADE AND AWAY FROM TREE ROOTS.
 - PROVIDE ALL HANGERS, INSERTS AND SUPPORTS OF APPROVED TYPES REQUIRED FOR THE WORK OF THIS DIVISION. PROVIDE CONDUIT FOR ALL SERVICES PUNCHING THE FLOOR SLAB. SEAL ALL PENETRATIONS THROUGH FLOOR SLABS WITH AN APPROVED NON-SINKING, WATERPROOF AND FIREPROOF SEALANT APPROVED BY ARCHITECT.
 - ALL CONDUIT SHALL BE MINIMUM BUT WITH STEEL SET SCREW COUPLERS AND CONNECTORS WITH INSULATED THROUS. UNLESS OTHERWISE NOTED INSIDE THE BUILDING, EXTERIOR EXPOSED CONDUIT SHALL BE RIGID OR FLEXIBLE CONDUIT. EXTERIOR EXPOSED CONDUIT SHALL BE RIGID PVC EXPOSED IMVISED (CONDUIT) IN FINISHED AREAS SHALL BE BRASS OR METAL CHANGES FOR SMALLER SIZES AND PARTED CONDUIT RUN NEXT IN APPEARANCE. RUN PARALLEL TO BUILDING LINES AND CONCEALING RIGHT ANGLE BENDS ONLY SHALL BE USED.
 - ALL WIRING SHALL BE COPPER BRANCH WIRING IN DRY LOCATIONS SHALL BE TWO IN WET LOCATIONS SHALL BE TWO AND EXTERIOR UNDERGROUND LOCATIONS SHALL BE THREE. FEEDER CABLES SHALL BE RIGID IN DRY LOCATIONS, FIBRO IN WET LOCATIONS AND RIGID FOR EXTERIOR UNDERGROUND RUN.
 - AFTER COMPLETION OF THE WORK, PROVIDE THE CONSULTANT TO REVIEW A SET OF REPRODUCIBLE AS-BUILT RECORD DRAWINGS PRIOR TO SUBMISSION TO OWNER. INCORPORATE ALL CHANGES ON AUTOCAD PLOTS.
 - PROVIDE MIN. OF 1 YEAR WARRANTY FOR THE SCOPE OF WORK.
 - ALL WORK SHALL BE DONE WITH MINIMUM POSSIBLE INTERFERENCE TO EXISTING BUILDING SYSTEMS AND IN THE TIME SCHEDULE FORWARDED. CONSULT WITH PROJECT MANAGER PRIOR TO PHASING.

00	ISSUED FOR SITE PLAN APPROVAL	2019-11-17
No.	DESCRIPTION	DATE
	ISSUED/REVISED	

PROFESSIONAL SEAL

ENGINEER
DAR ENGINEERING & DESIGN
 ELECTRICAL & MECHANICAL ENGINEERS

 148 Coatlina Drive,
 Brampton, ON, L6Y 0S2
 (416) 319-8371
 info@dareng.ca
 www.dareng.ca

CONTRACTOR TO CHECK AND VERIFY ALL WORK AND TO BE RESPONSIBLE FOR THE CORRECTNESS OF THE DRAWINGS FROM THE COMMENCEMENT OF THE WORK TO THE COMPLETION OF THE WORK.
 DO NOT SCALE THE DRAWING.
 ALL DIMENSIONS, SPECIFICATIONS AND NOTES SHALL BE THE PROPERTY OF THE ENGINEER AND MUST BE KEPT UNDER STRICT CONTROL. NO PARTS OF THIS DRAWING ARE TO BE REPRODUCED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN CONSENT OF THE ENGINEER.
 THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION UNLESS AUTHORIZED BY THE ENGINEER.

DRAWN BY: RY
APPROVED BY: RY
SCALE: AS NOTED
DATE: OCTOBER 2019
FILE NAME:

PROJECT:
PROPOSED DEVELOPMENT
N-E CORNER OF HURONTARIO & KING STREET, CALEDON, ON

DRAWING TITLE:
SITE LIGHTING PHOTOMETRIC LAYOUT

PROJECT NUMBER: P191024
SHEET NUMBER: E1.0