



October 24th, 2018

RECOGNITION FOR FIRE INSURANCE GRADING RECEIVED

Town of Caledon
Fire and Emergency Services

Superior Tanker Shuttle Service - Accredited

I am pleased to advise you that the above mentioned fire protection district within the province of Ontario was recently registered in the fire insurance grading index as being accredited for the delivery of Superior Tanker Shuttle Service.

The requirements for this accreditation are stringent and verify that the fire protection district is capable of delivering the minimum accepted fire flows to detached dwellings throughout the fire protection district and within 8 kilometres by road of the below accredited Fire Stations. This accreditation is an equivalency to the minimum requirements for hydrant protection, as set out by the insurance industry and the Fire Underwriters Survey.

Fire Underwriters Survey has provided information on fire protection and risk levels to the insurance industry in Canada since 1883. Fire Underwriters Survey was previously operated under the auspices of the Insurers Advisory Organization and CGI; however, is now operated by SCM Opta Information Intelligence.

Should you have any questions or concerns related to the Fire Underwriters Survey, the Superior Tanker Shuttle Service Accreditation process or any other related area, please contact the offices of Fire Underwriters Survey for further information.

Please note that this accreditation expires on October 26th, 2023 and is valid for the following fire stations:

Alton – F.S. #301	19630 Main Street, Alton, ON
Bolton – F.S. #302	28 Ann Street, Bolton, ON
Caledon East – F.S. #303	6085 Old Church Road, Caledon East, ON
Cheltenham – F.S. #304	14190 Creditview Road, Cheltenham, ON
Inglewood – F.S. #305	67 McKenzie Street, Inglewood, ON
Palgrave – F.S. #306	17177 Regional Road 50, Palgrave, ON
Snelgrove – F.S. #307	2 Snelcrest Drive, Snelgrove, ON
Mono Mills – F.S. #308	6000 Highway 9, Mono Mills, ON
Caledon Village – F.S. #309	3611 Charleston Sideroad, Caledon Village, ON



Personal Lines Fire Insurance Classification – DPG 3B(S) – Flow Rate of 261 IGPM

David Wilson
Public Fire Protection Specialist
Fire Underwriters Survey