



NOTES

1. WATERMAIN TO HAVE MINIMUM COVER OF 1.7m.
2. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
3. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLAN.
4. STREETLIGHT FIXTURE PER APPROVED TOWN STANDARD.
5. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION
 - 40 mm HL3
 - 65 mm HL8
 - 150 mm GRANULAR "A"
 - 300 mm GRANULAR "B"
6. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD.
7. ON A CRESCENT THE WATERMAIN SHALL BE PLACED ON THE OUTSIDE.
8. FULL LENGTH MINIMUM 100 MM DIA.SUB-DRAINS C/W FILTERCLOTH SHALL BE INSTALLED, AS PER APPROVED TOWN OF CALEDON STANDARD NO. 218.
9. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM 95% OF S.P.D. AT OPTIMUM MOISTURE CONTENT.
10. WHERE POSSIBLE MANHOLE LIDS TO BE LOCATED OUT OF TIRE LANE OF TRAFFIC.
11. LONG DIMENSION OF TRANSFORMER TO BE PARALLEL TO STREETLINE.

TOWN OF CALEDON 16.0m LOCAL WINDOW STREET 8.5m ROADWAY (7.9m PAVEMENT)	4	TEXT AND SLOPE REVISIONS	MAY 19	APR'D: C.C.	DATE: JUNE 08	
	3	DIMENSION AND TEXT REVISION	JAN. 09			
	2	DIMENSION AND LAYOUT REVISION	JULY 08	DRAWN:	SCALE: N.T.S.	
	1	DIMENSION EDIT, STD No. 212 NOW 201	JUNE 08	STANDARD No. 201		
	NO.	REVISION	APR'D			