

- 1. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
- 2. WATERMAIN TO HAVE MINIMUM COVER OF 1.7m.
- 3. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT **VERIFICATION**

40mm HL3

65mm HL8

150mm GRANULAR "A"

300mm GRANULAR 'B'

4. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD

- 5. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLAN
- 6. STREETLIGHT FIXTURE PER APPROVED TOWN STANDARD.
- 7. ON A CRESCENT THE WATERMAIN SHALL BE PLACED ON THE OUTSIDE.
- 8. FULL LENGTH MINIMUM 100MM DIA.SUB-DRAINS C/W FILTERCLOTH SHALL BE INSTALLED TO TOWN OF CALEDON STANDARD NO. 218.
- 9. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM 95% OF S.P.D. AT OPTIMUM MOISTURE CONTENT.
- 10. WHERE POSSIBLE MANHOLE LIDS TO BE LOCATED OUT OF TIRE LANE OF TRAFFIC.
- 11. ESTATE RESIDENTIAL 4.0 METERS LANE WIDTH.

TOWN OF CALEDON	5	TEXT AND SLOPE REVISIONS		JULY 19	APR'D: C.C. DATE: 19/01/00	
20.0m LOCAL URBAN/RURAL 9.3m ROADWAY (8.7m PAVEMENT)	4	DIMENSION AND TEXT REVISION		JAN. 09	APR'D: C.C. DATE: 19/01/00	
	3	DIMENSION, LAYOUT REVISION		JULY 08	drawn: BJM scale: N.T.S.	
	2	DIMENSION EDIT, STD No. 201 NOW 203		JUNE 08		
	1	OFFSETS		APRIL 08	STANDARD No. 203	
	NO.	REVISION	APR'D	DATE		