



**NOTES**

1. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9 m.
2. WATERMAIN TO HAVE A MINIMUM COVER OF 1.7 m.
3. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION
  - 40 mm HL3
  - 90 mm HL8
  - 150 mm GRANULAR "A"
  - 450 mm GRANULAR "B"
4. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD.
5. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLANS.
6. STREETLIGHT FIXTURE PER APPROVED TOWN STANDARD.
7. FULL LENGTH MINIMUM 100 MM DIA. SUB-DRAINS C/W FILTERCLOTH SHALL BE INSTALLED, AS PER APPROVED TOWN OF CALEDON STANDARD NO. 218.
8. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM 95% OF S.P.D. AT OPTIMUM MOISTURE CONTENT.
9. WHERE POSSIBLE MANHOLE LIDS TO BE LOCATED OUT OF TIRE LANE OF TRAFFIC.
10. LONG DIMENSION OF TRANSFORMER TO BE PARALLEL TO STREETLINE.
11. 1.0 m SPLASH PAD TO BE PATTERNED CONCRETE AS PER APPROVED TOWN OF CALEDON STANDARD NO. 903.

<b>TOWN OF CALEDON</b>  <b>20.0m NEIGHBOURHOOD COLLECTOR</b> <b>9.5m ROADWAY (8.9m PAVEMENT)</b>	4	TEXT AND SLOPE REVISION	JULY 19	APR'D: C.C.      DATE: JUNE 08  DRAWN:              SCALE: N.T.S.  <b>STANDARD No. 204</b>
	3	DIMENSION AND TEXT REVISION	JAN. 09	
	2	DIMENSION AND LAYOUT REVISION	JULY 08	
	1	DIMENSION EDIT, STD No. 206 NOW 204	JUNE 08	
	NO.	REVISION	APR'D	