



**NOTES:**

1. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
2. WATERMAIN TO HAVE MINIMUM COVER OF 1.7m.
3. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION  
 40mm HL3  
 90mm HL8  
 150mm GRANULAR "A"  
 450mm GRANULAR "B"
4. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD.
5. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLAN
6. STREETLIGHT FIXTURE PER APPROVED TOWN STANDARD.
7. ON A CRESCENT THE WATERMAIN SHALL BE PLACED ON THE OUTSIDE.
8. FULL LENGTH MINIMUM 100MM DIA.SUB-DRAINS C/W FILTERCLOTH SHALL BE INSTALLED AS PER TOWN OF CALEDON APPROVED STANDARDS NO. 218.
9. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM 95% OF S.P.D. AT OPTIMUM MOISTURE CONTENT.
10. WHERE POSSIBLE MANHOLE LIDS TO BE LOCATED OUT OF TIRE LANE OF TRAFFIC.

<b>TOWN OF CALEDON</b>	5	TEXT AND SLOPE REVISIONS	MAY 19	APR'D: <b>C.C.</b>	DATE: <b>JUNE 08</b>
	4	DIMENSION AND TEXT REVISION	JAN. 09		
<b>22m LOCAL THROUGH/URBAN 10.4m ROADWAY (9.8m PAVEMENT)</b>	3	DIMENSION AND LAYOUT REVISION	JULY 08	DRAWN:	SCALE: <b>N.T.S.</b>
	2	DIMENSION EDIT	JUNE 08		
	1	OFFSETS	APRIL 08		
	NO.	REVISION	APR'D	DATE	<b>STANDARD No. 205</b>