



NOTES

1. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9 m.
2. WATERMAIN TO HAVE A MINIMUM COVER OF 1.7 m.
3. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION
 40 mm HL3hs
 110 mm HDDB
 150 mm GRANULAR "A"
 450 mm GRANULAR "B"
4. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD.
5. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLANS.
6. STREETLIGHT FIXTURE PER APPROVED TOWN STANDARD.
7. FULL LENGTH MINIMUM 100 MM DIA.SUB-DRAINS C/W FILTERCLOTH SHALL BE INSTALLED, AS PER APPROVED TOWN OF CALEDON STANDARD NO. 218.
8. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM 95% OF S.P.D. AT OPTIMUM MOISTURE CONTENT.
9. WHERE POSSIBLE MANHOLE LIDS TO BE LOCATED OUT OF TIRE LANE OF TRAFFIC.
10. 1.0 m SPLASH PAD TO BE PATTERNED CONCRETE AS PER APPROVED TOWN OF CALEDON STANDARD NO. 903.
11. LONG DIMENSION OF TRANSFORMER TO BE PARALLEL TO STREETLINE.

TOWN OF CALEDON					APR'D: C.C.	DATE: JUNE 08
22.5m LOCAL INDUSTRIAL ROAD 11.0m ROADWAY (10.4m PAVEMENT)	4	TEXT AND SLOPE REVISION	APR. 19	STANDARD No. 206		
	3	DIMENSION, TEXT REVISION	JAN. 09			
	2	DIMENSION, LAYOUT REVISION	JULY 08			
	1	DIMENSION EDIT, STD No. 207.1 NOW 206	JUNE 08			
	NO.	REVISION	APR'D			DATE