



NOTES

1. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
2. WATERMAIN TO HAVE MINIMUM COVER OF 1.7m.
3. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION
 - 40mm HL3hs
 - 90mm HDBC
 - 150mm GRANULAR "A"
 - 450mm GRANULAR "B"
4. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD

5. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLAN.
6. STREETLIGHT FIXTURE PER APPROVED TOWN STANDARD.
7. ON A CRESCENT THE WATERMAIN SHALL BE PLACED ON THE OUTSIDE.
8. FULL LENGTH MINIMUM 100MM DIA. SUB-DRAINS C/W FILTER CLOTH SHALL BE INSTALLED AS PER TOWN OF CALEDON APPROVED STANDARDS NO. 218.
9. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM 95% OF S.P.D. AT OPTIMUM MOISTURE CONTENT.
10. WHERE POSSIBLE MANHOLE LIDS TO BE LOCATED OUT OF TIRE LANE OF TRAFFIC.
11. CENTER MEDIAN, HARD AND/OR SOFT LANDSCAPE TREATMENT AT THE DISCRETION OF THE TOWN.

TOWN OF CALEDON

24.0m URBAN - LOCAL DIVIDED ROAD
10.4m ROADWAY (9.8m PAVEMENT)

NO.	REVISION	APR'D	DATE	APR'D:	DATE:
4	TEXT AND SLOPE REVISION		MAY 19	C.C.	19/01/00
3	DIMENSION AND TEXT REVISION		JAN. 09	BJM	N.T.S.
2	DIMENSION AND LAYOUT REVISION		JULY 08		
1	DIMENSION EDIT, STD No. 220 NOW 207		JUNE 08		
				STANDARD No. 207	