



NOTES

1. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
2. WATERMAIN TO HAVE MINIMUM COVER OF 1.7m.
3. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION
 40mm HL3 HS
 110mm HDBC
 150mm GRANULAR "A"
 450mm GRANULAR "B"
4. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD
5. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLAN
6. STREETLIGHT FIXTURE PER APPROVED TOWN STANDARD.
7. ON A CRESCENT, THE WATERMAIN SHALL BE PLACED ON THE OUTSIDE.
8. FULL LENGTH MINIMUM 100mm DIA. SUB-DRAIN C/W FILTERCLOTH SHALL BE INSTALLED AS PER TOWN OF CALEDON APPROVED STANDARDS NO. 218.
9. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM OF 95% S.P.D. AT OPTIMAL MOISTURE CONTENT.
10. WHERE POSSIBLE, MANHOLE LIDS TO BE LOCATED OUT OF TIRE LANE OF TRAFFIC.
11. 1.0m SPLASH PAD TO BE 50mm IN DEPTH - HL3 ASPHALT.

TOWN OF CALEDON	7	TEXT AND SLOPE REVISIONS	APR. 19	APR'D: C.C. DATE: 29/01/00
	6	DIMENSION AND LAYOUT REVISION	JAN. 09	
24.0m LOCAL INDUSTRIAL ROAD 11.6m ROADWAY (11.0m PAVEMENT)	5	DIMENSION AND LAYOUT REVISION	JULY 08	DRAWN: BJM SCALE: N.T.S.
	4	DIMENSION EDIT, STD No. 207 NOW 208	JUNE 08	
	3	50mm HL3 ASPHALT SPLASH PAD	MAY 04	STANDARD No. 208
	2	BOULEVARD 3%	MAY 01	
	1	PAVEMENT STRUCTURE	FEB. 01	
	NO.	REVISION	APR'D	DATE