



- NOTES
1. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
  2. WATERMAIN TO HAVE MINIMUM COVER OF 1.7m.
  3. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION  
40mm HL3 HS  
110mm HDDB  
150mm GRANULAR "A"  
450mm GRANULAR "B"
  4. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD
  5. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLAN
  6. STREETLIGHT FIXTURE PER APPROVED TOWN STANDARD.
  7. ON A CRESCENT, THE WATERMAIN SHALL BE PLACED ON THE OUTSIDE.
  8. FULL LENGTH MINIMUM 100mm DIA. SUB-DRAINS C/W FILTERCLOTH SHALL BE INSTALLED AS PER TOWN OF CALEDON APPROVED STANDARDS NO. 218.
  9. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM OF 95% S.P.D. AT OPTIMAL MOISTURE CONTENT.
  10. WHERE POSSIBLE, AMNHOLE LIDS TO BE LOCATED OUT OF THE TIRE LANE OF TRAFFIC.
  11. 1.0m SPLASH PAD TO BE 50mm IN DEPTH - HL3 ASPHALT.

<b>TOWN OF CALEDON</b>  <b>26.0m LOCAL INDUSTRIAL ROAD</b> 10.4m ROADWAY (9.8m PAVEMENT)	4	TEXT AND SLOPE REVISION	APR. 19	APR'D: <b>C.C.</b>	DATE: 29/01/00
	3	DIMENSION AND TEXT REVISION	JAN. 09		
	2	DIMENSION AND LAYOUT REVISION	JULY 08	DRAWN: <b>BJM</b>	SCALE: N.T.S.
	1	DIMENSION EDIT, STD No. 208 NOW 209	JUNE 08		
	NO.	REVISION	APR'D	DATE	STANDARD No. 209