



NOTES:

1. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
2. WATERMAIN TO HAVE A MINIMUM COVER OF 1.7m.
3. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION.
 40mm HL3 HS
 90mm HDDB
 150mm GRANULAR 'A'
 450 GRANULAR 'B'
4. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND SURSERY SOD.

5. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLAN.
6. STREETLIGHT FIXTURE PER APPROVED TOWN STANDARD.
7. ON A CRESCENT, THE WATERMAIN SHALL BE PLACED ON THE OUTSIDE.
8. FULL LENGTH MINIMUM 100mm DIA. SUB-DRAINS C/W FILTERCLOTH SHALL BE INSTALLED AS PER TOWN OF CALEDON APPROVED STANDARDS NO. 218.
9. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM 95% S.P.D. AT OPTIMUM MOISTURE CONTENT.
10. WHERE POSSIBLE, MANHOLE LIDS TO BE LOCATED OUT OF THE TIRE LANE OF TRAFFIC.

TOWN OF CALEDON 26.0m URBAN - COLLECTOR FULL/PART SERVICES 10.4m ROADWAY (9.8m PAVEMENT)	5				APR'D: C.C.	DATE: 19/01/00
	4	TEXT AND SLOPE REVISION		APR 19	DRAWN: BJM	SCALE: N.T.S.
	3	DIMENSION AND TEXT REVISION		JAN. 09	STANDARD No. 210	
	2	DIMENSION AND LAYOUT REVISION		JULY 08		
	1	DIMENSION EDIT		JUNE 08		
NO.	REVISION	APR'D	DATE			