



NOTES

1. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9 m.
2. WATERMAIN TO HAVE A MINIMUM COVER OF 1.7 m.
3. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION
 - 40 mm HL3 HS
 - 110 mm HD3C
 - 150 mm GRANULAR "A"
 - 450 mm GRANULAR "B"
4. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD.
5. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLANS.
6. STREETLIGHT FIXTURE PER APPROVED TOWN OF CALEDON STANDARD.
7. FULL LENGTH MINIMUM 100 MM DIA. SUB-DRAINS C/W FILTERCLOTH SHALL BE INSTALLED, AS PER APPROVED TOWN STANDARD NO. 218.
8. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM 95% OF S.P.D. AT OPTIMUM MOISTURE CONTENT.
9. WHERE POSSIBLE MANHOLE LIDS TO BE LOCATED OUT OF TIRE LANE OF TRAFFIC.
10. 1.0 m SPLASH PAD TO BE PATTERNED CONCRETE AS PER APPROVED TOWN OF CALEDON STANDARD NO. 218.
11. LONG DIMENSION OF TRANSFORMER TO BE PARALLEL TO STREETLINE.

TOWN OF CALEDON 26.0m INDUSTRIAL COLLECTOR 14.5m ROADWAY (13.9m PAVEMENT)	4	TEXT AND SLOPE REVISION	APR 19	APR'D: C.C.	DATE: JUNE 08
	3	DIMENSION AND TEXT REVISION	JAN. 09		
	2	DIMENSION AND LAYOUT REVISION	JULY 08	DRAWN:	SCALE: N.T.S.
	1	DIMENSION EDIT, STD No. 209 NOW 211	JUNE 08		
	NO.	REVISION	APR'D	DATE	STANDARD No. 211