



NOTES

- UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
- WATERMAIN TO HAVE MINIMUM COVER OF 1.7m.
- THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION
 - 40mm HL3 HS
 - 110mm HD3C
 - 150mm GRANULAR "A"
 - 450mm GRANULAR "B"
- THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD
- TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLAN
- STREETLIGHT FIXTURE PER APPROVED TOWN STANDARD.
- ON A CRESCENT, THE WATERMAIN SHALL BE PLACED ON THE OUTSIDE
- FULL LENGTH MINIMUM 100mm DIA. SUB-DRAINS C/W FILTERCLOTH SHALL BE INSTALLED AS PER TOWN OF CALEDON APPROVED STANDARDS NO. 218.
- SUB-GRADE SHALL BE COMPACTED TO A MINIMUM 95% OF S.P.D. AT OPTIMUM MOISTURE CONTENT.
- WHERE POSSIBLE, MANHOLE LIDS TO BE LOCATED OUT OF TIRE LANE OF TRAFFIC.
- 1.0m SPLASH PAD TO BE 50mm IN DEPTH - HL3 ASPHALT.

TOWN OF CALEDON 30.0m ARTERIAL ROAD 7.6m - 15.6m ROADWAY 7.0m - 15.0m ASPHALT SURFACE	4	TEXT AND SLOPE REVISION	APR 19	APR'D: C.C.	DATE: 29/11/99
	3	DIMENSION AND TEXT REVISION	JAN. 09	DRAWN: BJM	SCALE: N.T.S.
	2	DIMENSION AND LAYOUT REVISION	JULY 08	STANDARD No. 212	
	1	DIMENSION EDIT, STD No. 217 NOW 212	JUNE 08		
NO.	REVISION	APR'D	DATE		