



NOTES:

1. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
2. WATERMAIN TO HAVE A MINIMUM COVER OF 1.7m.
3. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION.
 40mm HL3 HS
 90mm HDDB
 150mm GRANULAR "A"
 450mm GRANULAR "B"
4. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD.
5. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLAN.
6. STREETLIGHT FIXTURE PER APPROVED TOWN STANDARD.
7. ON A CRESCENT, THE WATERMAIN SHALL BE PLACED ON THE OUTSIDE.
8. FULL LENGTH MINIMUM 100mm DIA. SUB-DRAINS C/W FILTERCLOTH SHALL BE INSTALLED AS PER TOWN OF CALEDON APPROVED STANDARDS NO. 218.
9. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM 95% S.P.D. AT OPTIMAL MOISTURE CONTENT.
10. WHERE POSSIBLE, MANHOLE LIDS TO BE LOCATED OUT OF TIRE LANE OF TRAFFIC.

TOWN OF CALEDON	5			APR'D: C.C.	DATE: 26/06/19
30.0m URBAN - COLLECTOR 4 LANES 15.6m ROADWAY (15m PAVEMENT)	4	TEXT AND SLOPE REVISIONS	APR 19	DRAWN:	SCALE: N.T.S.
	3	DIMENSION AND TEXT REVISION	JAN. 09		
	2	DIMENSION AND LAYOUT REVISION	JULY 08	STANDARD No. 213	
	1	DIMENSION EDIT, STD No. 211 NOW 213	JUNE 08		
	NO.	REVISION	APR'D		