



NOTES:

1. CENTRELINE OF TRENCH TO BE LOCATED 3.05m FROM PROPERTY LINE AS PER MUNICIPAL SPECIFICATIONS.
2. BASE OF TRENCH TO BE LINED WITH 100mm OF CLEAN MASON SAND.
3. 100mm OF CABLE SAND FROM EDGE OF TRENCH AND CABLES. 150mm OF CABLE SAND BETWEEN PRIMARY AND SECONDARY.
4. BACKFILL TO CONSIST OF ADDITIONAL 150mm OF CLEAN MASON SAND, COMPACTED. CLEAN NATIVE MATERIAL COMPACTED TO TOP OF TRENCH.
5. WARNING TAPE TO BE PLACED PRIOR TO PLACING THE FINAL 150mm OF SAND BACKFILL
6. ALL SEPARATIONS AND DEPTHS OF BURIAL ARE MINIMUM.
7. A MINIMUM OF 50mm OF CLEAN MASON SAND IS REQUIRED AROUND ALL CABLES.
8. SPARE DUCTS TO PLACED WITH THE COMMUNICATIONS CABLES, FOR FUTURE USE BY THE TOWN OF CALEDON. REFER TO TOWN STANDARDS MANUAL, SECTION 1.14.1 FOR DETAILS.

TOWN OF CALEDON				APR'D: C.C.	DATE: FEB. 05
JOINT USE UTILITY CORRIDOR	3	SPARE DUCTS AND TEXT REVISION	MAY 19	DRAWN: A.P.	SCALE: NTS
	2	DIMENSION AND TEXT REVISION	JAN 18		
	1	STANDARD No. 600 NOW 220	JUNE 08	STANDARD No. 219	
	NO.	REVISION	APR'D		