



**NOTES**

1. WATERMAIN TO HAVE MINIMUM COVER OF 1.7m.
2. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
3. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLAN.
4. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION
  - 40 mm HL3
  - 65 mm HL8
  - 150 mm GRANULAR "A"
  - 300 mm GRANULAR "B"

6. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD.
8. FULL LENGTH MINIMUM 100 MM DIA.SUB-DRAINS C/W FILTERCLOTH SHALL BE INSTALLED.
9. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM 95% OF S.P.D. AT OPTIMUM MOISTURE CONTENT.
10. WHERE POSSIBLE MANHOLE LIDS TO BE LOCATED OUT OF TIRE LANE OF TRAFFIC.
- 11.LONG DIMENSION OF TRANSFORMER TO BE PARALLEL TO STREETLINE.

TOWN OF CALEDON					APR'D:	DATE: MAY 19
PRIVATE ROAD CROSS SECTION STANDARD CONDOMINIUM ROAD					DRAWN: J.M.	SCALE: N.T.S.
		NO.	REVISION	APR'D	DATE	STANDARD No. 222