



**NOTES**

1. WATERMAIN TO HAVE MINIMUM COVER OF 1.7m.
2. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
3. TREES TO BE PLACED IN LOCATIONS PER APPROVED LANDSCAPE PLAN.
4. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION
  - 40 mm HL3
  - 65 mm HL8
  - 150 mm GRANULAR "A"
  - 300 mm GRANULAR "B"

6. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL AND NURSERY SOD.
8. FULL LENGTH MINIMUM 100 MM DIA.SUB-DRAINS C/W FILTERCLOTH SHALL BE INSTALLED,
9. SUB-GRADE SHALL BE COMPACTED TO A MINIMUM 95% OF S.P.D. AT OPTIMUM MOISTURE CONTENT.
10. WHERE POSSIBLE MANHOLE LIDS TO BE LOCATED OUT OF TIRE LANE OF TRAFFIC.
11. LONG DIMENSION OF TRANSFORMER TO BE PARALLEL TO STREETLINE.

TOWN OF CALEDON				APR'D:	DATE: MAY 19
	PRIVATE ROAD CROSS SECTION COMMON ELEMENT CONDOMINIUM ROAD			DRAWN: J.M.	SCALE: N.T.S.
				STANDARD No. 223	
NO.	REVISION	APR'D	DATE		