



NOTES:

1. MINIMUM TRENCH WIDTH TO BE 900mm.
2. GRANULAR A BEDDING (OR APPROVED EQUIVALENT) TO BE USED 350mm EITHER SIDE OF CROSSOVERS TO SPRINGLINE OF UPPER PIPE. MINIMUM 150mm GRANULAR MATERIAL COVER REQUIRED OVER PIPE.
3. 125mm DIA. TEST FITTING TO BE MARKED 'STORM'.
4. STORM CONNECTION TO MAINLINE TO BE WHITE.
5. STORM CONNECTION TO BE ON THE LEFT WHEN FACING THE HOUSE.
6. STORM SERVICE CONNECTION TO BE SECURELY CAPPED AND EXTEND 1.5M BEYOND PROPERTY LINE.

TOWN OF CALEDON				APR'D: C.C.	DATE: DEC 1999
SERVICE CONNECTION IN COMMON TRENCH	2	DRAWING AND TEXT REVISIONS	APR 19	DRAWN: BJM	SCALE: NTS
	1	STANDARD No. 705 NOW 502	JUNE 08	STANDARD No. 502	
	NO.	REVISION	APR'D		