



**NOTES:**

1. EXCAVATE TO 325mm MINIMUM DEPTH, CONTRACTOR SHALL BE RESPONSIBLE FOR THE REMOVAL AND REPLACEMENT OF ANY UNSUITABLE SUBGRADE MATERIAL SUCH AS TOPSOIL. REMOVE ALL EXCAVATED MATERIAL AND DISPOSE OF OFF SITE.
2. ALL DIMENSIONS IN MILLIMETRES.
3. ASPHALT AND GRANULAR BASE AMOUNT SPECIFICATIONS ARE MINIMUM AFTER COMPACTION.
4. SLOPE SUBGRADE PARALLEL TO FINISHED GRADE (MIN. 2% SLOPE).
5. WIDTH OF PATH TO BE IDENTIFIED ON LANDSCAPE PLANS.
6. THE BASKETBALL COURT ASPHALT SHALL BE INSTALLED IN TWO LIFTS WITH:
  - 50mm HL8 BASE COAT AND
  - MINIMUM 30mm HL3A TOP COAT

TOWN OF CALEDON					APR'D: C.C.	DATE: JUNE 08
ASPHALT PAVING WALKWAY DETAIL OR MULTI-USE COURT	2	TEXT UPDATE		AUG 19	DRAWN: B.B.	SCALE: N.T.S.
	1	STD 224 NOW STD 901		APR 19	STANDARD No. 901	
	NO.	REVISION	APR'D	DATE		